

CERTIFICATE OF COMPLIANCE

Certificate Number 20131212-EX15873
Report Reference EX15873-20131212
Issue Date 2013-DECEMBER-12

Issued to: GOLAN PLASTIC PRODUCTS LTD
Kibbutz Shaar Hagolan
15145 Jordan Valley ISRAEL

**This is to certify that
representative samples of**


CROSS-LINKED POLYETHYLENE PIPE
Underground fire service mains, Pexgol Pipe, nominal pipe
sizes 1/2, 5/8, 3/4, 1, and 3 in., for working pressures not
exceeding 160 psig.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1285, Pipe and Couplings, Polyvinyl Chloride (PVC),
and Oriented Polyvinyl Chloride (PVCO) for Underground
Fire Service
UL 1713, Pressure Pipe and Couplings, Glass Fiber-
Reinforced, for Underground Fire Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

